

1981-12-10

U.B.C. School of Nursing
Acute Care Hospital
2211 Wesbrook Mall
Vancouver, BC
V6T 1W6

DEC 14 1981

A.U.C.E.

Attention: Mrs. June Prenty

Dear Mrs. Prenty:

This will confirm our conversation with Teresa Rostworowski during the inspection of your Research Room on 1981 November 25.

The enclosed booklet "Working with Video Display Terminals" provides useful guidelines to providing VDT workstations that will reduce the incidence of visual and musculoskeletal-induced discomfort and fatigue experienced by VDT operators.

Special attention should be given to the quality, quantity, and positioning of light fixtures and to the control of indirect glare sources such as light coloured walls, furniture and equipment.

In addition to this, repositioning of the light fixtures in the general office in relation to task locations would reduce the visual discomfort in this area.

Please advise the undersigned when improvements have been completed and, do not hesitate to request additional information if required.

Yours truly

Ralph L. Robson
Inspector

RLR/sas

Enclosure

cc. ✓ Mr. Wolfgang Felix
Maintenance Dept.
Acute Care Hospital
2211 Wesbrook Mall
Vancouver, BC
V6T 1W6

Carole Cameron
AUCE Local 1
#202 - 6383 Memorial Road
UBC
Vancouver, BC
V6T 1W5