



1981-11-19

RECEIVED

NOV 23 1981

A.U.C.E.

U.B.C. Faculty of Forestry  
Off Campus Programs  
2360 Health Sciences Mall  
Vancouver, BC  
V6T 1W5

Attention: Carol Cummings  
Assistant Director

Further to the inspection of your premises on 1981-11-04,  
and our conversation at that time, the following corrective  
measures are required to comply with the Factory Act and  
Regulations of British Columbia.

1. Ventilation

Provide a mechanical ventilation system capable  
of supplying outdoor air to the occupied spaces  
at a rate of not less than 20 c.f.m. per person,  
or 140 c.f.m. per 1000 square feet of floor area,  
whichever is greater.

This supply air shall be distributed in such a  
way that delivery is assured to each occupied  
space, and shall be circulated, uninterrupted,  
at all times that the building is in use.

As discussed, due to wind conditions and for  
security reasons, the use of openable windows  
is not recommended.

Completion of the above is required within a reasonable  
period of time. A reply advising us of completion, or your  
schedule for this work is required within thirty (30) days.

For further information or clarification, please contact  
the undersigned.

Yours truly

Ralph L. Robson  
Inspector

RLR/sas

cc. C. P. Smellie  
Supt. Mechanical Utilities  
Operations & Maintenance Division  
Dept. of Physical Plant  
2210 West Mall  
Vancouver, BC

✓ Carole Cameron  
Union Organizer  
AUCE Local 1  
#220-6383 Memorial Road, UBC  
Vancouver, BC